VAN-MET® FIRE-RATED ACCESS DOOR

MODEL FCB-250 - THREE HOUR, INSULATED FOR WALL OR CEILING APPLICATION

SPECIFICATIONS

MATERIAL: SATIN FINISH GALVANIZED (BONDERIZED) STEEL

PANEL: 1.31 mm (18ga), SELF-CLOSING

LINER: 0.85 mm (22ga) FRAME: 1.61 mm (16ga)

FLANGE: GALVANIZED STEEL DRYWALL BEAD TAPING

FLANGE

HINGE: CONTINUOUS ROD HINGE


LATCH: 1/4" ALLEN KEY, WITH INTERIOR RELEASE 63mm (2 1/2"") HIGH TEMPERATURE INSULATION:

FINISH: PRIME COAT, OFF-WHITE

OPTIONS (CHECK OFF REQUIRED OPTIONS)

- ☐ RAISED KNURLED KNOB
- ☐ NON-LOCKING HANDLE
- ☐ 1 1/8" MORTISE PREP ONLY
 - ☐ CYLINDER PROVIDED BY MAXAM
 - ☐ CYLINDER PROVIDED BY OTHERS
- ☐ CONTINUOUS PIANO HINGE
- $\ \square$ 304 STAINLESS STEEL WITH A NO. 4 POLISHED FINISH ON THE

EXTERIOR SURFACE




FRONT ELEVATION





WARNOCK HERSEY LISTED FOR 2 HOUR WALLS; ① TEMPERATURE RISE MAXIMUM 139°C / 250°F AT 30 MINUTES, ② 250°C / 450°F AT 60 MINUTES (3) WARNOCK HERSEY LISTED FOR 3 HOUR CEILINGS.

UNITED STATES BUILDING CODE NATIONAL BUILDING CODE OF CANADA LISTED FOR UNITED STATES AND CANADA



MAXAM **METAL PRODUCTS**

Maxam Metal Products Ltd. Unit 5 - 7978 North Fraser Way Burnaby, BC, Canada V5J 0C7

Tel: 604-433-4243 Fax: 604-433-4148

Website: www.maxammetal.com Email: info@maxammetal.com

PROJECT: **CONTRACTOR:**

SECTION A-A

ARCHITECT:			
DRAWN BY:	DATE:	QUANTITY:	TITLE:
KJK	01/01/2003		FCB-150.DWG

^{*} Specifications subject to change without notice.